

SADDLEBACK VALLEY UNIFIED SCHOOL DISTRICT

RFP #17-03

DATA CENTER UPS REPLACEMENT- Erate

ADDENDUM 1

QUESTIONS FROM BIDDERS:

1. Are there existing electrical plans for the data center and electrical room?

No

2. Will the bypass switch be located on the same wall as the current electrical panel in the data center?

Yes

3. Will the UPS system also power air conditioning units when on utility or battery?

No

4. How many air conditioning units cooling the data center?

2x 7.5-ton units